

Industrial Wastewater Pretreatment Monitoring Report

Sampling Point #2 (Part 1, A&B)

Milbank Mfg

Year 01 Month FEB.

Date	Flow	pH	Cd	Cr	Cu	Ni	Ag	Pb	Zn	Mo	TTO	Phenol	CN	TPH	FOG	NH3	CBOD	COD	TSS
1	2630	9.46							.062	4.020						4.1	712	4500	35
2																			
3																			
4																			
5																			
6	980	9.50																	
7	2240	9.41																	
8	2600	9.47							.071										
9																			
10																			
11																			
12																			
13	1810	9.68																	
14	2320	9.51																	
15																			
16																			
17																			
18																			
19																			
20	1290	9.80																	
21	1430	9.62																	
22	1160	9.66																	
23																			
24																			
25																			
26	1000	9.58																	
27	1960	9.53																	
28	3110	9.70																	
29																			
30																			
31																			
Daily LIMIT	N/A	N/A	.02	2.0	.6	.8	.24	.1	1.25	N/A	2.13	.5	.5	N/A	100	N/A	N/A	N/A	N/A
Average	1878	9.57							.066							4.1	18	4500	35
Maximum	3110	9.80							.071							4.1	24	4500	35
Minimum	980	9.41							.062							4.1	712	4500	35

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief is, true, accurate and complete. I am aware there are significant penalties for submitting false information, including the possibility of fines and imprisonment for knowing violations."

Richard Lyle
Authorized Company Representative

DATE 03-16-01

MIL0003642